

# Heatless Modular Desiccant Air Dryers **DHDM Series**





# **Optimal System Protection**

The Deltech DHDM Series Modular Desiccant Air Dryers protect moisture sensitive applications requiring low pressure dew points. Delivers dew points of ISO 8573-1: 2010 Class 1 (-94°F, -70°C) and Class 2 (-40°F, -40°C) with flow rates of 3 to 177 scfm (4.8 to 284 nm<sup>3</sup>/h). Critical applications include labs, hospitals, pharmaceutical manufacturing and other high-tech installations.

The DHDM Series incorporate a time proven design, with superior features and reliability, in a compact and easy to install package. Standard features include:

## 300 Series Filter Packages Standard

- Grade H3 coalescing prefilter captures oil down to 0.008 mg/m³
- Grade P3 afterfilter removes solids 1.0 micron and larger

# **Technology At A Glance**

- Consistent outlet pressure dew points
- Selectable pressure dew point performance for maximum application flexibility
- Minimum purge air usage saves energy
- Desiccant beds sized to prevent fluidization plus slow and complete regeneration prevents desiccant aging
- Non-lubricated, soft seated control valves promotes reliable operation
- Heavy duty purge exhaust muffler for quiet operation

# **Highly Accurate Solid State Timer**

- Standard 4 minute cycle time delivers
- Flow deration delivers ISO Quality Class 1 pressure dew point

# **Front Mounted Control Panel**

- Electronic controls to monitor status & operation
- Power on light
- Tower indicator lights
- On-off switch

# Supreme Craftsmanship

- Powder coasted cabinet for long term durability
- Fully assembled, piped and wired eases installation
- Extruded aluminum columns to house desiccant cartridges
- Supplied with 6' (1.8 m) power cord
- Flexible installation with multiple inlet/outlet options
- Floor mount support for secure installation

## **Extended Warranty**

- One-year warranty standard
- Up to five-year warranty with purchase of annual maintenance kit



- ISO Quality Class 2 pressure dew point



**02 / DHDM Series** Heatless Modular Desiccant Air Dryers



# **Product Specifications**

	FLOW RATE @100 PSI	DIMENSIONS						IN/OUT	WEIGHT	
MODEL		١	н	w		D		CONNECTIONS	WEIGHT	
	SCFM	in	mm	in	mm	in	mm	NPT	lbs	kg
DHDM 3	3	16.7	424.2	9.4	238.8	8.3	210.8	3/8"	21.8	9.9
DHDM 9	9	32.4	822.9	9.4	238.8	8.3	210.8	3/8"	35	15.9
DHDM 15	15	42.2	1071.9	9.4	238.8	8.3	210.8	3/8"	46	20.9
DHDM 24	24	38.1	967.7	18.7	474.9	14.3	363.2	1/2″	101.5	46.1
DHDM 32	32	44	1117.6	18.7	474.9	14.3	363.2	3/4"	121.2	54.9
DHDM 41	41	51.9	1318.3	18.7	474.9	14.3	363.2	3/4"	136.7	62
DHDM 59	59	65.9	1673.9	18.7	474.9	14.3	363.2	1″	180.8	82
DHDM 88	88	73.7	1871.9	18.7	474.9	14.3	363.2	1″	186.5	84.6
DHDM 118	118	67.1	1704.3	21.1	535.9	19.5	495.3	1-1/2"	352.7	160
DHDM 147	147	75	1905	21.1	535.9	19.5	495.3	1-1/2"	396.8	180
DHDM 177	177	75	1905	21.1	535.9	19.5	495.3	1-1/2"	396.8	180

Dryers are certified for quality and safety to CSA C22.2 No.0-10, C22.2 No.14-18 & UL 508.

# **Dew Point Performance**

ISO CI	_ASS 2	ISO CLASS 1			
Pressure Dew Point	Cycle Time	Pressure Dew Point	Cycle Time		
-40°F (-40°C)	8 minutes: 4 minutes drying 4 minutes regenerating	-94°F (-70°C)	4 minutes: 2 minutes drying 2 minutes regenerating		

- DHDM series dryers operate automatically in producing a dehydrated gas stream
- User selectable ISO 8573.1 : 2010 Compressed Air Quality Class 2 (-40°F, -40°C) and (-94°F, -70°C) Class 1 pressure dew point
- At ISO 7183 (A2) conditions: Remaining water content at Class 1 pressure dew point: 0.002%
- At ISO 7183 (A2) conditions: Remaining water content at Class 2 pressure dew point: 0.2%
- ISO Class 1 requires 86°F (30°C) inlet air temperature






# •

### **How It Works**

Compressed air enters the dryer and is directed to Tower 1 by valve (A) to be dried, and then to the dryer outlet through shuttle valve (B). A portion of the dried air is throttled to near atmospheric pressure by means of orifice (C). This extremely dry, low pressure air flows through and regenerates the desiccant in Tower 2 and is exhausted through purge/repressurization valve (D) and exhaust muffler (E) to atmosphere. After a set time, the automatic solid state timer closes purge/repressurization valve (D) allowing Tower 2 to repressurize slowly. At the end of 2 minutes, valve (A) shifts and purge/repressurization valve (D) reopens.





## - Inlet & Purge Flow Correction Factors

Inlet	psig	50	70	90	100	110	120	130	150
Pressure	kg/cm	3.5	4.9	6.3	7	7.7	8.4	9.1	10.5
MULTIPL	IER A	0.31	0.54	0.83	1.00	1.09	1.17	1.26	1.44
MULTIPL	IER B	0.55	0.73	0.91	1.00	1.09	1.17	1.26	1.44

- 1 Inlet flows are established in accordance with CAGI (Compressed Air and Gas Institute) standard ADF-200, Dual Stage Regenerative Desiccant Compressed Air Dryers Methods for Testing and Rating. Conditions for rating dryers are: inlet pressure 100 psig (7 kg/cm2); inlet temperature saturated at 100°F (38°C).
- 2 Average Purge Flow is the total amount of air used to purge and repressurize off-stream towers averaged over the cycle time.

  Maximum Purge Flow is the flow rate through the off-stream tower during that portion of the cycle the purge/repressurization valve is open.

# **Capacity Correction Factors**

- To determine maximum inlet flow at inlet pressures other than 100 psig (7 kg/cm²), multiply inlet flow from Table 1 by multiplier A from Table 2 that corresponds to system pressure at inlet of dryer.
- To determine purge flow at inlet pressures other than 100 psig (7 kg/cm²), multiply purge flow at 100 psig (7 kg/cm²), from Table 1 by multiplier B from Table 2 that corresponds to system pressure at inlet of dryer.
- To determine outlet flow capacity, subtract purge flow from inlet flow.

# Heatless Modular Desiccant Air Dryers **DHDM Series**

3 to 177 scfm (4.8 to 284 nm $^3$ /h)

Design features, materials of construction and dimensional data, as described in this bulletin, are provided for your information only and should not be relied upon unless confirmed in writing. Please contact your local sales representative for product availability in your region.

# **Deltech Headquarters**

4647 SW 40th Avenue Ocala, Florida 34474-5788 U.S.A.

**Tel.:** (724) 745-1555 **Fax:** (724) 745-6040

deltechair.com



© Copyright Deltech 2024 DT\_DHDM\_US/10-2024/CI