


Specification

1. The compressor must have at least 4 feet of clearance on all sides for adequate ventilation and cooling.
2. The compressor must be installed on a smooth, level surface capable of supporting the gross weight of the machine.

UNLESS OTHERWISE SPECIFIED									
TOLERANCE ON ANGLES: +/- 0.5 DEGREE							KRSP-350 FS		Outline Dimensions
MACHINED PARTS TOLERANCE: +/- 0.03 in							PHASE SIGN	WEIGHT	SCALE
SHEETMETAL TOLERANCE: +/- .13 in							S		1:1
FINISH ON MACHINED SURFACES $\nabla 12.5$							SHEET	1	OF 1
DESIGN		STD						REF. ONLY	
CHECK		AUDITING						NEXT ASSE	
		APPROVE							