

32in 813mm 00000

SPECIFICATIONS							
HORSEPOWER	7.5						
OPERATING PRESSURE (PSI)	115-145						
AIR DELIVERY (CFM)	19.0						
CONTROL SYSTEM	MULTIPLE UNIT CONTROL - AUTO START/STOP						
NOISE LEVEL dB(A)	70						
AIR OUTLET (BALL VALVE)	1/2" NPT						
OPERATING VOLTAGE	3 PHASE, 208-230/460V, 60 Hz						
DIMENSIONS (L x W x H)	75 x 32 x 55						
APPROX. WEIGHT (LBS)	TBD						





		NAME	DATE	ANEST IWATA Air Engineering Inc.			A	VEST	
	DRAWN	BSC	01/25/22			■ IWA		MTA	
	CHECKED	TD	01/25/22	TITLE:					
	ENG APPR.			OFT-7.5H-FRD-80)	1
	MFG APPR.								
UNLESS OTHERWISE SPECIFIED:	Q.A.			OIL-FREE PISTON UNIT TANK MOUNT COMPRESSOR & DRYER					
	COMMENTS:								
			SIZE	DWG. NO.			REV		
				В	OFT-7.5H-FF	RD-80-1	Гххх		
DO NOT SCALE DRAWING				SCA	LE: 1:20 WEIGHT:		SHEET	1 OF 1	

NOTES:

1) COMPRESSOR UNIT MUST BE INSTALLED IN A ROOM ON A FLAT FLOOR

2) COMPRESSOR IS AN AIR COOLED UNIT - ROOM TEMPERATURE MUST NOT EXCEED 104° F
EXHAUST DUCTS OR VENTILATING FAN MUST BE INSTALLED IF ROOM TEMPERATURE EXCEEDS 104° F

3) PROVIDE ADEQUATE SPACE DURING INSTALLATION FOR NECESSARY MAINTENANCE AND REPAIRS
ALLOW A MINIMUM OF 20" ON EACH SIDE AND 24" FROM TOP OF UNIT FROM WALLS

4) CARE MUST BE TAKEN TO INSURE COMPRESSOR UNIT DOES NOT INTAKE HOT AIR OR DUST 5) REFER TO INSTRUCTION MANUAL FOR ELECTRIC WIRING DIAGRAM

6) SPEC IS SUBJECT TO CHANGE WITHOUT NOTICE

D

D

3

PROPRIETARY AND CONFIDENTIAL THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF

REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF

ANEST IWATA. ANY

ANEST IWATA IS