



**NOTES:**  
DESIGNED, WELDED, INSPECTED TO ASME CODE  
SECTION VIII DIV 1, U STAMP WITH NB  
REGISTRATION 285 PSIG @ -20 TO +100 DESIGN  
HYDRO TEST-428 PSIG  
CS CONSTRUCTION (EXCEPT AS NOTED)  
8" 150# RFSO CONNECTIONS  
1/2" NPT VENT  
1/2" NPT DRAIN CONNECTION  
1/4" NPT GAUGE CONNECTION  
INTERNAL FINISH: WHITE ENAMEL  
EXTERNAL FINISH: AIRCEL BLUE ENAMEL

REPLACEMENT ELEMENT: AG3040098  
FILTER MEDIA: POLYESTER, FELT FILTER MEDIA; 0.3  $\mu$  RETENTION  
UPSTREAM/DOWNSTREAM FILTER JACKETS  
PERFORATED CORE

**PROPRIETARY AND CONFIDENTIAL**  
THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF  
AIRCEL LLC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE  
WRITTEN PERMISSION OF AIRCEL LLC IS PROHIBITED.

UNLESS OTHERWISE SPECIFIED:		NAME		DATE				COMPRESSED AIR AND GAS PRODUCTS 323 CRISP CIRCLE MARYVILLE TENNESSEE 37801 PHONE: 865-681-7066 FAX: 865-681-7069		
DIMENSIONS ARE IN INCHES TOLERANCES: FRACTIONAL ± 0.125 ANGULAR: ±0.5° TWO PLACE DECIMAL ± .03 THREE PLACE DECIMAL ± .003  THIRD ANGLE PROJECTION		DRAWN	O.P.	05/02/19	TITLE:  MIS-6500, 8IN FLG CONN					
		CHECKED	M.S.	05/02/19						
		ENG APPR.								
		MFG APPR.								
		Q.A.								
MATERIAL		COMMENTS:			SIZE		DWG. NO.		REV	
FINISH					B		AG3040089		0	
DO NOT SCALE DRAWING					SCALE: 1:10		WEIGHT:		SHEET 1 OF 1	